

NSF/ANSI Testing Results

Fuji Clean USA model CE5 (545-gal tank. Power use, 1.3 kWh per day)

ANSI/NSF 40 Data

450-gpd, straight septic, no septic tank.

BOD/CBOD (mg/l)		TSS (mg/l)		Nutrients					
				Total Nitrogen (1 sample/week)			Total Phosphorus (1 sample/week)		
Influent (Avg)	Effluent (Avg)	Influent (Avg)	Effluent (Avg)	Influent (Avg)	Effluent (Avg)	% Removal	Influent (Avg)	Effluent (Avg)	% Removal
152	11	259	13	24	10	62%	9	7	22%

Fuji Clean USA Model CEN5 (749-gal tank. Power use, 1.3 kWh per day)

ANSI/NSF 40/245 Data

450-gpd, straight septic, no septic tank.

BOD/CBOD (mg/l)		TSS (mg/l)		Total Nitrogen		Fecal Coliform (w/ UV) Total Colonies /100 mL
Influent (Avg)	Effluent (Avg)	Influent (Avg)	Effluent (Avg)	Influent (Avg)	Effluent (Avg)	Effluent (Geomean)
190	5	305	6	40	10	70



Certified to
NSF/ANSI Standards 40 & 245