



Paul R. LePage, Governor
Tel. (207) 287-2070

Mary C. Mayhew, Commissioner

Department of Health and Human Services
Maine Center for Disease Control and Prevention
286 Water Street
11 State House Station
Augusta, Maine 04333-0011
Tel. (207) 287-8016
Fax (207) 287-9058; TTY (800) 606-0215
Fax (207) 287-4172

October 12, 2016

Fuji Clean, LLC
Attn.: Bennette D. Burkes, P.E.
1518 Willow Lawn Drive, Suite 300
Hnerico, VA 23230

Subject: Modified Approval for General Use, Fuji Clean System, CE and CEN Series

Dear Mr. Burkes:

The Division of Environmental and Community Health has reviewed your proposal for reductions in disposal field sizing and reduced separation form limiting factors for systems which incorporate the Fuji Clean System, CE and CEN Series (Fuji Clean) wastewater treatment systems. This request is predicated upon the ability of the Fuji Clean system to produce BOD5 and TSS levels below 10 mg/l, each.

The Division approves the request for reduced disposal field area and reduced separation distances as follows:

1. A minimum separation distance of 12 inches shall be maintained between the seasonal high groundwater table and the lowest elevation of the system's disposal field;
2. A minimum separation distance of 12 inches shall be maintained between bedrock and the lowest elevation of the system's disposal field;
3. Stone beds and trenches are allowed a 75 percent reduction in size, based upon the standard sizing requirements of the Rules;
4. Proprietary devices such as but not limited to plastic chambers and gravel-less pipe trenches are allowed a 50 percent reduction in size based upon the standard sizing requirements of the Rules, absent prohibitions by manufacturers;
5. Eljen GSF units may be used with Fuji Clean systems, but with no reduction in size; and
6. Maintenance agreement contracts must be included with all system installations. Terms and duration of the contracts shall be in accordance with Fuji Clean's company policies.

Because installation and maintenance has a significant effect on the working order of onsite sewage disposal systems, including their components, the Division makes no representation or guarantee as to the efficiency and/or operation of this system. Further, the Division strongly recommends that property owners enter into long term maintenance contracts with Fuji Clean, in accordance with Fuji Clean's company policies.

Should you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in blue ink that reads "James A. Jacobsen". The signature is written in a cursive style with a long horizontal flourish extending to the right.

James A. Jacobsen
Project Manager, Webmaster
Division of Environmental Health
Drinking Water Program
Engineering Review Team
e-mail: james.jacobsen@maine.gov

/jaj

xc: File