

DAVID Y. IGE
GOVERNOR OF HAWAII



VIRGINIA PRESSLER, M.D.
DIRECTOR OF HEALTH

STATE OF HAWAII
DEPARTMENT OF HEALTH
P. O. BOX 3378
HONOLULU, HI 96801-3378

In reply, please refer to:
File:
Fuji Clean USA
NSF ANSI 40_Cert Acknwldgmt.ltr

June 2, 2015

Mr. Richard A. Chiodini, Manager
Clear Water Solutions LLC
c/o Septic Preservation Services
35 Harold Sweet Drive
Attleboro, MA 02703

Dear Mr. Chiodini:

**Subject: Fuji Clean USA, LLC - Models CE5, CE7, CE10, and CEN5
NSF/ANSI Standard 40 – Residential Wastewater Treatment Systems
NSF/ANSI 245 – Wastewater Treatment Systems, Nitrogen Reduction
NSF International Product Certification Listing**

The Department of Health (DOH) acknowledges the receipt of your notification letter of NSF certification and attached documents for the Fuji Clean USA, LLC Models CE5, CE7, CE10, and CEN5 on April 9, 2015. The DOH confirmed that, as of date of this letter, the Fuji Clean USA, LLC Models CE5, CE7, and CE10 have been NSF certified to meet the performance requirements of NSF/ANSI Standards 40. Also, the DOH acknowledges that the Fuji Clean USA, LLC Model CEN5 has been NSF certified to have met the performance requirements of NSF/ANSI Standards 40 and 245.

Accordingly, the DOH approves of the Fuji Clean USA, LLC Models CE5, CE7, CE10, and CEN5 as NSF/ANSI Standard 40 certified aerobic treatment unit that may be used in the State of Hawaii based on the following requirements:

Models CE5 and CEN5 may serve a dwelling unit not to exceed two bedrooms or a non-residential building not to exceed 450 gallons per day (gpd) of wastewater flow.

Model CE7 may serve a dwelling unit not to exceed three bedrooms or a non-residential building not to exceed 630 gpd of wastewater flow.

Model CE10 may serve a dwelling unit not to exceed four bedrooms or a non-residential building not to exceed 900 gpd of wastewater flow.


It should be noted that Hawaii Administrative Rules, Chapter 11-62, does not include specific specifications for individual wastewater systems to achieve NSF/ANSI Standard 245 requirements.

Mr. Richard A. Chiodini
June 2, 2015
Page 2

Please be informed that the design and construction of all wastewater systems including the incorporation of the Fuji Clean USA, LLC Models CE5, CE7, CE10, and CEN5 must conform to applicable provisions of the Hawaii Administrative Rules, Chapter 11-62, "Wastewater Systems."

Should you have any questions, please contact Mr. Mark Tomomitsu of my staff at (808) 586-4294.

Sincerely,

A handwritten signature in blue ink, appearing to read "Sina Pruder", written in a cursive style.

SINA PRUDER, P.E., CHIEF
Wastewater Branch

MST:lmj

C: Mr. Richard A. Chiodini, Clear Water Solutions LLC (via email: rchiodini@cox.net)