



**DIRECTOR'S JOURNAL ENTRY  
APPROVAL OF FUJI CLEAN CEN SERIES**

The Fuji Clean CEN Series models CEN5, CEN7, CEN10, and CEN21 have been reviewed by this department. This review and approval process as authorized under section 3718.04 of the Ohio Revised Code is intended to ensure pretreatment component reliability and effluent quality are achieved and maintained in accordance with the standards and provisions of Ohio Administrative Code (O.A.C.) Chapter 3701-29. In accordance with O.A.C. 3701-29-13(K) the Director may approve pretreatment components that demonstrate compliance with the CBOD<sub>5</sub>/TSS standard in paragraph (A) of rule 3701-29-14 of the Administrative Code through ANSI/NSF Standard 40 certification by an ANSI/CSA accredited third party certifier.

The Fuji Clean CEN models listed have achieved certification with current ANSI/NSF Standard 40 certification by an accredited ANSI/CSA third party. Ohio Department of Health approval is hereby granted for the following pretreatment components and treatment trains submitted by Fuji Clean in accordance with section 3718.04 of the Ohio Revised Code:

- Fuji Clean CEN Series models CEN5, CEN7, CEN10, CEN21 for achieving the CBOD<sub>5</sub> standard of <25 mg/L and the TSS standard of <30 mg/L.

Any additional requests from the application not specifically approved by the Director are hereby denied.

Manufacturers are required to provide adequate product and service support to owners, designers, installers, and service providers. Local health districts shall require service contracts for these pretreatment components to assure proper operation and maintenance. Manufacturers must provide system owner access to service providers qualified and available to conduct operation and maintenance on approved pretreatment components.

Pretreatment components are subject to Ohio Department of Health review for compliance with the conditions of approval and applicable law and rules. A pretreatment component may be reevaluated at any time when there is evidence of noncompliance with approval conditions, for other reasons deemed necessary to assure compliance, and upon request of the manufacturer. Upon review, if there is a determination of noncompliance, a pretreatment component approval may be revoked. The revocation of an approval pursuant to section 3718.04 of the Ohio Revised Code may be appealed in accordance with Chapter 119 of the Ohio Revised Code.

You may request an administrative hearing to challenge this Journal Entry, pursuant to section 3718.04(D) and Chapter 119 of the Revised Code. Your request for a hearing may be delivered to the

Department of Health via facsimile, hand-delivery, or United States mail; but, must be made in writing, and must be received by the Ohio Department of Health within thirty days of the mailing of the Journal Entry. Please direct your written request to: Office of the General Counsel, Ohio Department of Health, 246 North High Street, 7<sup>th</sup> Floor, Columbus, Ohio 43215. At any hearing, you may appear in person or be represented by your attorney, and you may present evidence and examine witnesses appearing for and against you. You may also present your position, arguments, or contentions in writing. If you are a corporation, you must be represented at the hearing by an attorney licensed to practice in the state of Ohio.

Amy Acton /s/  
Amy Acton, M.D., MPH  
Director of Health

3/21/19  
Date

I hereby certify this to be a true and correct copy of the Journal Entry of the Director of the Ohio Department of Health.

3/22/2019  
Date

Brenda M. Adams  
Custodian of the Director's Journals  
Ohio Department of Health