

Bryan W. Shaw, Ph.D., P.E., *Chairman*
Toby Baker, *Commissioner*
Jon Niermann, *Commissioner*
Richard A. Hyde, P.E., *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

October 27, 2017

Mr. Scott Samuelson
Manager
Fuji Clean USA, LLC
41 Greenwood Road, Suite 2
Brunswick, ME 04011
United States

RE: Approval of the Fuji Clean USA, LLC, CE Series CE5, CE7, CE10, CE14 and the CEN series CEN5, CEN7 and CEN10. Revised 11/16/2017 for a non-technical, addressing, error.

Dear Mr. Samuelson,

The staff of the Texas Commission on Environmental Quality has completed our review of the NSF International (NSF) report on the subject product line. Based on the NSF report, the units have been approved for use in the State of Texas. Approval of the units, along with approval of the training materials, was completed October 23, 2017.

The CE series units are rated at 450, 630, 900 and 1,000 gallons per day treatment capacity respectively. The CEN series units are rated at 450, 630 and 900 gallons per day treatment capacity respectively.

The approved product listing will note that the subject units do include pretreatment chambers. Separate pretreatment tanks will not be required for use in Texas. Also, the units do not include pump chambers. All pump tanks, are subject to the requirements specified in 30 TAC 285.34(b).

This letter will serve as verification of your approval until the CE and CEN series of treatment units is listed on the TCEQ website. If you have any questions concerning our review, please contact me by telephone at (512) 239-2150, by E-mail at mprice@tceq.state.tx.us or by facsimile at (512) 239- 6390. When responding by mail, please be sure to use mail code MC-235.

Sincerely,

A handwritten signature in blue ink, appearing to read "Michael Price".

Michael Price
On-site Sewage Program

CC: Bennette D. Burks