

Steve Sisolak
Governor

Richard Whitley, MS
Director



DEPARTMENT OF
HEALTH AND HUMAN SERVICES
Division of Public and Behavioral Health
Helping people. It's who we are and what we do.



Lisa Sherych
Administrator

Ihsan Azzam, Ph.D., M.D.
Chief Medical Officer

13 October 2020

Scott Samuelson
Fuji Clean USA, LLC
41-2 Greenwood Road
Brunswick, ME 04011

Re: Fuji Clean USA CE and CEN Series, Plan Review AC-140-24431 and AC-140-24427

Mr. Lentz,

The residential use of the Fuji Clean USA CE and CEN Series Models as a primary treatment unit in Nitrogen Reduction Areas has been approved.

The units will be placed on the list of approved septic tanks and components at the next update and posted to the ISDS program webpage at http://dpbh.nv.gov/Reg/ISDS/Individual_Sewage_Disposal_Systems_-_Home/.

Sincerely,

A handwritten signature in blue ink that reads "Scott W. Burt".

Scott Burt, RESHT

Environmental Health Specialist II

Encls (1): Fuji Clean CE and CEN Series Sizing Chart.

Cc: Teresa R. Hayes, Program Manager, Environmental Health
Washoe County Health District
Carson City Health & Human Services
Southern Nevada Health District

Fuji Clean CE and CEN Series Sizing Chart.

MODEL		RATED FLOW (GPD)	BEDROOMS (~125 GPD/BR)
CE5	CEN5	500	4
CE7	CEN7	700	6
CE10	CEN10	1,000	8
CE14	CEN14	1,350	11
CE21	CEN21	1900	16
CE30		2,700	22
CE6KG		6,000	48